

2018年6月废水在线日数据

日期	COD(100mg/l)		NH3-N(15mg/l)		总氮(20mg/l)	
	排放平均浓度 mg/l	排放量kg	排放平均浓度 mg/l	排放量kg	排放平均浓度 mg/l	排放量kg
2018/6/1	16.87	17.23	6.09	6.24	9.51	9.73
2018/6/2	15.79	17.13	6.23	6.77	8.63	9.36
2018/6/3	15.92	15.69	6.43	6.33	7.66	7.54
2018/6/4	14.73	13.13	5.65	5.01	7.36	6.56
2018/6/5	17.34	13.83	5.16	4.13	7.41	5.92
2018/6/6	16.85	17.94	4.7	4.97	6.77	7.21
2018/6/7	15.71	16.81	4.54	4.82	7.18	7.67
2018/6/8	18.16	19.3	4.53	4.83	7.47	7.9
2018/6/9	17.81	16.11	4.51	4.1	7.4	6.71
2018/6/10	16.91	17.95	4.66	4.95	6.92	7.31
2018/6/11	14.68	15.67	4.79	5.12	6.58	7.05
2018/6/12	16.43	17.55	4.76	5.1	6.6	7.05
2018/6/13	17.72	18.04	4.57	4.65	6.39	6.5
2018/6/14	17.02	14.3	4.6	3.83	6.9	5.8
2018/6/15	17.19	15.64	4.61	4.18	7.16	6.53
2018/6/16	17.5	18.72	4.76	5.1	7.54	8.05
2018/6/17	15.46	14.57	4.64	4.36	7.59	7.16
2018/6/18	13.92	13.36	4.53	4.35	7.88	7.52
2018/6/19	16.04	15.55	4.2	4.04	8.01	7.79
2018/6/20	18.84	15.49	3.37	3.05	7.52	6.16
2018/6/21	15.32	14.36	4.41	4.14	7.53	7.05
2018/6/22	15.11	14.01	4.87	4.53	8.06	7.46
2018/6/23	17.13	18.45	4.79	5.15	8.2	8.83
2018/6/24	17.17	12.24	4.63	3.35	8.27	5.89
2018/6/25	14.21	2.56	4.22	0.76	8	1.42
2018/6/26	12.71	1.15	3.45	0.32	7.72	0.68
2018/6/27	15.98	3.83	3.48	0.83	7.85	1.88
2018/6/28	17.78	1.92	3.53	0.47	8.13	0.89
2018/6/29	18.43	0.92	3.02	0.24	8.99	0.5
2018/6/30	16.50	16.85	4.2	4.29	10.71	10.96

废水流量t/d
1020.83
1086.11
984.75
891.19
797.57
1064.49
1067.28
1062.19
905.16
1061.7
1068
1068.21
1017.64
839.66
910.35
1069.92
942.74
960.11
969.83
821.25
938.22
926.73
1076.95
713.14
182.18
89.2
239.29
107.86
50.45
1022.29

四川永祥股份有限公司2018年6月委托监测结果公示

监测日期	监测项目	监测点位	排放限值	监测结果
2018年6月6日	5日生化需氧量	废水总排口	30mg/l	3.2mg/l
	悬浮物	废水总排口	70mg/l	6mg/l
	硫化物	废水总排口	1mg/l	<0.005mg/l
	氯乙烯	废水总排口	2mg/l	<0.5mg/l
	汞及其化合物	氯乙烯尾气排放口	0.012mg/m ³	0.003mg/m ³