

四川永祥股份有限公司2019年5月废水自动监测结果

QR-AH-12.14-2019

日期	COD(60mg/l)		NH3-N(15mg/l)		总氮(20mg/l)		废水流量t/d
	排放平均浓度 mg/l	排放量kg	排放平均浓度 mg/l	排放量kg	排放平均浓度 mg/l	排放量kg	
2019/5/1	14.63	16.32	9.89	11.04	13.22	14.75	1115.21
2019/5/2	12.38	13.83	9.43	10.52	12.56	14.01	1116.16
2019/5/3	11.70	12.05	8.73	8.97	11.67	12.03	1028.14
2019/5/4	11.53	10.45	8.45	7.64	10.55	9.53	904.56
2019/5/5	12.03	10.6	8.2	7.21	10.94	9.62	879.79
2019/5/6	15.70	13.88	8.15	7.21	11.11	9.8	883.51
2019/5/7	18.31	16.48	6.89	6.17	10.95	9.87	900.33
2019/5/8	16.12	17.91	6.58	7.34	10.49	11.64	1111.78
2019/5/9	17.80	18.36	6.58	6.8	10.61	10.93	1031.07
2019/5/10	18.61	15.7	6.38	5.4	9.79	8.26	843.11
2019/5/11	15.33	14.38	6.63	6.21	9.85	9.24	938.26
2019/5/12	12.69	13.84	6.89	7.5	10.14	10.61	1091.36
2019/5/13	12.69	9.64	7	4.7	9.37	11.04	670.93
2019/5/14	14.37	20.03	6.94	8.11	9.94	6.29	1166.03
2019/5/15	17.15	19.12	7.28	8.55	9.83	11.59	1173.57
2019/5/16	15.95	18.77	7.92	9.32	9.98	11.75	1177.1
2019/5/17	13.56	13.41	8.21	8.13	10.04	9.93	898.6
2019/5/18	17.79	17.79	7.98	8.68	9.74	10.55	1083.96
2019/5/19	19.08	19.08	7.07	7.87	10.16	11.33	113.76
2019/5/20	19.59	11.83	7.04	4.26	10.4	6.28	604.5
2019/5/21	15.97	15.67	7.16	7.02	10.1	9.92	982.5
2019/5/22	15.62	17.3	7.09	7.83	9.76	10.79	1108.04
2019/5/23	17.39	14.83	6.95	5.92	8.66	7.34	852.19
2019/5/24	12.40	13.35	7.81	8.42	8.34	8.95	1077.01
2019/5/25	12.66	14.28	7.93	8.96	8.48	9.56	1128.81
2019/5/26	12.10	9.51	8.02	6.3	8.29	6.51	787.76
2019/5/27	16.89	16.84	8.23	8.21	8.31	8.28	996.98
2019/5/28	11.67	12.02	8.55	8.8	8.66	8.93	1029.14
2019/5/29	15.27	14.41	8.75	8.27	8.55	8.09	944.58
2019/5/30	27.26	24.52	8.71	7.8	8.47	7.6	898.72
2019/5/31	22.98	21.52	7.49	7.01	8.59	8.05	936.8